

A1 FIRST FLOOR LIGHTING PLAN - BUILDING A (ADDITION)
1/8" = 1'-0"

GENERAL NOTES

1. LIGHTING CONTROLS AND LUMINAIRES DESIGNATED WITH LOWER CASE LETTERS INDICATE WHICH LUMINAIRE(S) SHALL BE CONTROLLED BY EACH LIGHTING CONTROL DEVICE.
2. LIGHTING CONTROLS AND LUMINAIRES LOCATED WITHIN ENCLOSED SPACES WITHOUT LOWER CASE LETTER DESIGNATIONS SHALL CONTROL LUMINAIRES WITHIN THE SPACE, UNLESS OTHERWISE NOTED.

KEY NOTES

1. CONNECT TO THE NEAREST EXISTING EXTERIOR EMERGENCY LIGHTING CIRCUIT (EHLP195-9).
2. CONNECT TO THE EXISTING SPARE IN PANEL HLP193(20A, 1 POLE BREAKER 277V) IN THE ELECTRICAL ROOM 193 FOR NORMAL POWER.

GRAPHIC SCALE(S)

1/8" = 1' - 0" 0 5' 10' 15' 30'

SHARON ELEMENTARY SCHOOL ADDITION

4330 Foxcroft Rd.
Charlotte, NC 28211

Charlotte-Mecklenburg Schools

DESIGNER

CLARKNEXSEN

1111 METROPOLITAN AVE, SUITE 333
CHARLOTTE, NORTH CAROLINA 28204
704-377-8800 LICENCE#C-1028

TIMMONS GROUP
YOUR VISION ACHIEVED THROUGH OURS.

2030 TRYON STREET, STE 3C
CHARLOTTE, NC 28203
T: 704.376.1073

PROFESSIONAL SEAL

NORTH CAROLINA
SEAL
021538
ENGINEER
PATRICK J. ROSE

2020.03.30 15:59:30-04'00'

SUBMITTAL

FEBRUARY 19, 2020

FOR CONSTRUCTION ONLY

REVISIONS

1	03/30/20	REVIEW CYCLE 2 /ADDENDUM #2

KEY PLAN



SHEET

FIRST FLOOR LIGHTING PLAN - BUILDING A (ADDITION)

E402

DESIGN: AJM
DRAWN: AJM
REVIEW: Checker

CN 8418

3/30/2020 3:48:47 PM
C:\Revit Projects\8418_CMS SHARON E20200309_454_FAIJuheshi@clarknexsen.com.rvt
400