

HOSE PULL TABLE

A TO B -	456 FT
B TO C -	192 FT
B TO D -	125 FT
E TO F -	745 FT
F TO D -	178 FT
F TO G -	116 FT
H TO I -	200 FT

NOTE:

FIRE ACCESS DRIVE IS CAPABLE OF SUPPORTING AN 80,000 LB FIRE APPARATUS

EXISTING FIRE ACCESS DRIVE DETAIL

NOT TO SCALE

SHARON ELEMENTARY SCHOOL ADDITION

4330 Foxcroft Road
Charlotte, NC 28211

cms
Charlotte-Mecklenburg Schools

DESIGNER

CLARKNEXSEN

1111 Metropolitan Avenue, Suite 333
Charlotte, NC 28204
704.377.8800

CONSULTANT

TIMMONS GROUP
ENGINEERING | DESIGN | TECHNOLOGY

610 E. Morehead Street, Suite 250
Charlotte, NC 28202
704.602.8600

PROFESSIONAL SEAL

SEAL 3/27/20 ENGINEER BRIAN V. CRUTCHFIELD

NC Corporate Engineering License #: C-1652

SUBMITTAL

February 19, 2020

FOR CONSTRUCTION ONLY

REVISIONS

0	10-16-19	SD SUBMITTAL
1	11-06-19	50% DD SUBMITTAL
2	12-11-19	100% DD SUBMITTAL
3	01-09-20	50% CD SUBMITTAL
4	01-28-20	95% CD SUBMITTAL
5	03-04-20	CITY COMMENTS
6	03-13-20	REVIEW CYCLE 1
8	03-27-20	BID ADDENDUM 2

SHEET

FIRE ACCESS PLAN

C301

DESIGN: BVC
DRAWN: RAS
REVIEW: BVC

CN 8414

S:\194\14616-Sharon_Elem_School\DWG\Sheet\C01\14616C-301-FIRE.dwg Mon, 30 Mar 2020 - 9:38am rayon.samuels