



Certificate of Compliance

Certificate: 2137671

Master Contract: 244391

Project: 70159063

Date Issued: 2018-06-11

Issued to: Flow Management Devices, LLC.
5225 S. 37th St. Suite 4
Phoenix, Arizona 85040
USA
Attention: Paul Deschamps

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Jack Chin*
Jack Chin

PRODUCTS

CLASS - C321806 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - For Hazardous Locations

CLASS - C321886 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus-For Hazardous Locations-Certified to U.S. Standards

**Class I, Division 1, Group D;
Class I, Division 2, Group D;
Maximum Operation Ambient 40°C**

Small Volume Prover, Models XXXXXX(XX)XXXX#XXXXX where X may be any alphanumeric character to designate mechanical options not affecting safety.

Permanently connected, control/interface circuit 24Vdc, 500mA.

For #:

- 1 = model with three enclosures, Div 1
- 5 = model with three enclosures, Div 2
- A = model with one enclosure, Div 1
- C = model with one enclosure, Div 2
- E = model with two enclosures, Div 1
- G = model with two enclosures, Div 2