



### ASSEMBLY LIST

- ① 6"φ INLET, FLANGED
- ② 6"φ OUTLET, FLANGED
- ③ 4"φ FPT DUPLEX SERVICE FITTING
- ④ 2'-6"φ MANWAY W/ (2) FPT FITTINGS
- ⑤ COALESCING MEDIA
- ⑥ SLUDGE BAFFLE
- ⑦ 4"φ FPT MONITOR FITTING OR OPTIONAL HYDROSTATIC RESERVOIR (DW ONLY)
- ⑧ LIFTING LUGS
- ⑨ OPTIONAL PREFABRICATED DEADMAN

|               |   |
|---------------|---|
| SCALE: N.T.S. | DATE: 12/23/14  |
|               | THIS DRAWING AND SPECIFICATION IS THE PROPERTY OF OWS TECHNOLOGIES, 1109 25TH STREET WEST PALM BEACH, FL. 33407 AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION. |
| DRAWN BY: TMB | CHECKED BY:   |

**OIL WATER SEPARATOR**  
**TECHNOLOGIES, LLC**  
 1109 25TH STREET W.P.B., FL. 33407

|                                 |  |
|---------------------------------|--|
| MODEL: HB-F-10-20K-1 114 G.P.M. | OWS JOB No. -  |
| JOB: OWS TECHNOLOGIES           | DRAWING No. 4S5128<br>FILE: 10-20K-114-SWDW 12/23/14 |

### WEIGHTS & CAPACITIES

10'φ - 20,000 GAL. TANK SW OR DW  
 NOMINAL WGT. SW 10,900#  
 NOMINAL WGT. DW 13,400#  
 MAX. SPILL CAPACITY 12,000 GAL.