



ASSEMBLY LIST

- 1 14"Ø INLET, FLANGED
- 2 14"Ø OUTLET, FLANGED
- 3 4"Ø FPT DUPLEX SERVICE FITTING
- 4 2'-6"Ø MANWAY W/ (2) FPT FITTINGS
- 5 COALESCING MEDIA
- 6 SLUDGE BAFFLE
- 7 4"Ø FPT MONITOR FITTING OR OPTIONAL HYDROSTATIC RESERVOIR (DW ONLY)
- 8 LIFTING LUGS
- 9 OPTIONAL PREFABRICATED DEADMAN

THIS DRAWING AND SPECIFICATION IS THE PROPERTY OF OWS TECHNOLOGIES 1109 25TH STREET WEST PALM BEACH, FL. 33407 AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION.

SCALE: N.T.S. DATE: 12/23/14

DRAWN BY: TMB CHECKED BY:

**OIL WATER SEPARATOR
TECHNOLOGIES, LLC**

1109 25TH STREET W.P.B., FL. 33407

MODEL: HB-F-10-20K-13 1,482 G.P.M.

JOB: OWS TECHNOLOGIES

OWS JOB No. -

DRAWING No. 4S5116

FILE: 10-20K-1482-SWDW 8/26/14

WEIGHTS & CAPACITIES

10'Ø - 20,000 GAL. TANK SW OR DW
 NOMINAL WGT. SW 10,900#
 NOMINAL WGT. DW 13,400#
 MAX. SPILL CAPACITY 12,000 GAL.