



### ASSEMBLY LIST

- ① 10"Ø INLET, FLANGED
- ② 10"Ø OUTLET, FLANGED
- ③ 4"Ø FPT DUPLEX SERVICE FITTING
- ④ 2'-6"Ø MANWAY W/ (2) FPT FITTINGS
- ⑤ COALESCING MEDIA
- ⑥ SLUDGE BAFFLE
- ⑦ 4"Ø FPT MONITOR FITTING OR OPTIONAL HYDROSTATIC RESERVOIR (DW ONLY)
- ⑧ LIFTING LUGS
- ⑨ OPTIONAL PREFABRICATED DEADMAN

SCALE: N.T.S.  
DATE: 12/23/14

THIS DRAWING AND SPECIFICATION IS THE PROPERTY OF OWS TECHNOLOGIES, 1109 25TH STREET WEST PALM BEACH, FL. 33407 AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION.

DRAWN BY: TMB  
CHECKED BY:

**OIL WATER SEPARATOR**  
**TECHNOLOGIES, LLC**

1109 25TH STREET W.P.B., FL. 33407

MODEL: HB-F-10-20K-4 456 G.P.M.

JOB: OWS TECHNOLOGIES

OWS JOB No. -  
DRAWING No. 4S5125  
FILE: 10-20K-456-SWDW 12/23/14

### WEIGHTS & CAPACITIES

10'Ø - 20,000 GAL. TANK SW OR DW  
 NOMINAL WGT. SW 10,900#  
 NOMINAL WGT. DW 13,400#  
 MAX. SPILL CAPACITY 12,000 GAL.