

Facility Planning Data Sheet

7011A Series 6 - 12 kVA UPS (208/120 or 240/120)

Power Rating		UPS AC Input (208V or 240V)								Battery System			AC Out (208V or 240V)		Mechanical Information				
		Voltage		kVA		Current		Minimum Input AWG	External Overcurrent Protection	Nominal Voltage	Full Load kW	Maximum Discharge	Current Nominal	External Overcurrent Protection	Dimensions W x D x H	Weight Lbs	Floor Loading Lbs/ Ft2	Heat Rejection kBTU/ Hr	Cooling Air CFM
		Vac/ Freq.	Nom.	Max.	Nom.	Max.													
6	4.2	208/120 / 60Hz	4.9	6.36	20.3	26.5	8 AWG or larger	35A	216 VDC	4.5	26.1	25.0	35A	13.8 x 29.9 x 27.8	307	107	2.0	210	
6	4.2	240/120 / 60Hz	4.9	6.36	20.3	26.5	8 AWG or larger	35A	216 VDC	4.5	26.1	25.0	35A	13.8 x 29.9 x 27.8	307	107	2.0	210	
8	5.6	208/120 / 60Hz	6.5	8.48	27.1	35.3	8 AWG or larger	45A	216 VDC	6.0	34.8	33.3	45A	13.8 x 29.9 x 40.6	507	177	2.6	280	
8	5.6	240/120 / 60Hz	6.5	8.48	27.1	35.3	8 AWG or larger	45A	216 VDC	6.0	34.8	33.3	45A	13.8 x 29.9 x 40.6	507	177	2.6	280	
10	7	208/120 / 60Hz	8.1	10.6	33.8	44.2	6 AWG or larger	60A	216 VDC	7.5	43.6	41.7	60A	13.8 x 29.9 x 40.6	507	177	3.3	350	
10	7	240/120 / 60Hz	8.1	10.6	33.8	44.2	6 AWG or larger	60A	216 VDC	7.5	43.6	41.7	60A	13.8 x 29.9 x 40.6	507	177	3.3	350	
12	8.4	208/120 / 60Hz	9.7	12.7	40.6	53.0	4 AWG or larger	70A	216 VDC	9.0	52.3	50.0	70A	13.8 x 29.9 x 40.6	507	177	3.9	410	
12	8.4	240/120 / 60Hz	9.7	12.7	40.6	53.0	4 AWG or larger	70A	216 VDC	9.0	52.3	50.0	70A	13.8 x 29.9 x 40.6	507	177	3.9	410	
Notes:				1	2	3,9,12,A,B,C		4,7,10	5		6,12	1	4,7,8,10	10,11	13				

Notes:

1. Nominal (Nom.) current based on rated load.
2. Maximum (Max.) current based on converter overload rating.
3. Input and output cables typically run in separate conduits.
4. If initial load is less than UPS' rated output, it is recommended that AC input, battery, and AC output wiring and overcurrent protection be sized to UPS' full load rating to accommodate possible future expansion.
5. Nominal battery voltage assumed to be 2.0 volts/cell (lead technology).
6. If user provided, DC cables should be sized for not more than a 2.0% line drop at maximum discharge current.
7. Suggested AC output overcurrent protection based on continuous full load current per NEC 210-20. 80% rated breakers assumed.
8. Grounding conductors to be sized per NEC Article 250-122 and NEC Table 250-122. Neutral conductors to be sized per NEC Article 310-15.
 - AC Input: 1 ϕ , 3 wire + ground.
 - AC Output: 1 ϕ , 3 wire + ground.
 - DC Input: If user supplied, 2 wire (Positive and Negative) + ground.
9. All wiring to be in accordance with all applicable national and/or local electrical codes.
10. Minimum access clearance per UPS drawings or Owner's Manual.
11. Cable entry from rear. Punch plates accordingly. (*Consult MEPPi for alternate entry/exit points.*)
12. Control wiring and power wiring to be run in separate conduits.
13. Includes weight of internal batteries.

Additional Notes:

- i. For site configurations including emergency generators, engine generator to be sized and equipped for UPS applications. Generator equipped with governor for frequency regulation and regulator for voltage stability recommended. Note: UPS' reflected current distortion is 3% max at full load and 6% max at 50% load.
 - ii. For site configurations equipped with an external Maintenance Bypass Switch circuit, UPS must be on internal Static Bypass before transferring to external Maintenance Bypass. Consult Factory for further information.
- A. Not more than 3 conductors in raceway assumed; ambient temperature of 30 °C (86 °F) assumed.
- B. Temperature rating of conductors: 75 °C (167 °F). Reference Table 310-16 of NEC, 75 °C column, using copper conductors. 75 °C (167 °F) cable terminal connectors assumed.
- C. Reference: NEC handbook 1999. Consult local codes for possible variations.
- D. RATINGS OF CABLES AND OVERCURRENT DEVICES SUPPLIED FOR INFORMATION ONLY. USER TO CONSULT WITH ITS ENGINEERING SERVICES BEFORE ADOPTING.**

