

## ADDENDUM No. 2 TO CONTRACT DOCUMENTS

### DOUGLAS COUNTY SEWER IMPROVEMENT DISTRICT No. 1

Muller Lane East Brockliss Slough Bridge Sewer Force Main Relocation Project

Contract B – Line Connections and Isolation Valve (PWP No. DO-2017-271)

October 9, 2017

*THE BIDDER SHALL EXECUTE THE CERTIFICATION WITHIN THE BID FORM ACKNOWLEDGING RECEIPT OF THIS ADDENDUM.*

\*\*\*\*\*

\*\*\*\*\*

### CLARIFICATIONS

1. A 12-inch 350 PSI rated Gate Valve with handwheel operator is an acceptable substitution for the 12-inch Full Port Plug Valve.



END OF ADDENDUM No. 2

Prepared By:  
R.O. ANDERSON ENGINEERING, INC.  
1603 Esmeralda Avenue  
Minden, NV 89423