

**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS
FOR
MITCHELL BANK STABILIZATION PROJECT
FOR
MASON VALLEY CONSERVATION DISTRICT**

DECEMBER 10, 2018

*THE BIDDER SHALL EXECUTE THE CERTIFICATION WITHIN THE BID FORM
ACKNOWLEDGING RECEIPT OF THE ADDENDUM.*

Plan Holder List:

1. The current plan holder list as of the date of this addendum is attached as Exhibit A.

Pre-Bid Attendance:

2. The attendees of the pre-bid meeting are listed in the attached Exhibit B.

Points of Clarification:

3. Compaction testing requirements are not required for this project. However, the Owner's representative will visually observe the compaction to make sure that the constructed slopes are stable.
4. CADD files will be provided if requested by the Contractor after signing required paper work.
5. Dewatering is required near Site 1 (longer bank stabilization area). Dewatering may not be required near Site 2 (shorter bank stabilization area).
6. As mentioned in the Contract Documents, the Owner will provide willow bundles and labor. The Contractor is required to provide required supervision for installation. The Owner will also provide required safety equipment to the willow installers.
7. Cottonwood trees will be supplied by the Owner for the log veins installation. However, the Contractor is required to haul them from the source location to the job site. The source location for the cottonwood tree is within 10 mile range from the project site.
8. The log veins can not be replaced with rock stream barbs and the log veins need to be installed as shown on the improvement plans.

9. Temporary crossing near Site 2 (shorter bank stabilization area) will be difficult to permit through the United States Army Corps Engineers (USACE) and therefore is not allowed.
10. Prevailing wages are not mandatory for this project as the engineer's estimate is well below the \$250,000 threshold that would trigger such a requirement.
11. Erosion Control Blanket quantity is expected to be about 9,000 sf.
12. The Owner will provide required native seed mix for the Contractor to install.

Prepared By:
R.O. ANDERSON ENGINEERING, INC.
1603 Esmeralda Avenue
P.O. Box 2229
Minden, Nevada 89423

Smith Valley & Mason Valley Conservation District
1518-003-17
Mitchell Bank Stabilization Project
PLAN HOLDERS LIST

| COMPANY | CONTACT / EMAIL | ADDRESS | PHONE/ FAX | NO. | ADD. |
|---------------------------------------|--------------------------------------------------------------------------------------------|-----------------------------------------------|--------------------------------------------|------------|-------------|
| Crocket Enterprises | crockettent@gmail.com | 1101 Sawmill Rd, Gardnerville, NV 89410 | 782-7640 (o) 782-7602 (f) | 1 | Paid \$50 |
| Mason Valley Conservation District | Ed Ryan paul.ryan@nv.usda.gov | 215 West Bridge St., #11A Yerington, 89447 | 775-223-7499 | 2 | Client |
| R.O. Anderson Engineering | Shaker Gorla sgorla@roanderson.com | 1603 Esmeralda Ave Minden, NV 89423 | 775-782-2322 | 3 | Engineer |
| Sierra Contractor's Source | | 860 Maestro Dr Reno, NV 89511 | 775-329-7222 | 4 | Online |
| Burdick Exc Co | Ralph Kellogg rkellogg@burdkcikexc.com | | 530-362-1089 775-296-4566 (o) | 5 | Online |
| Desert Engineering | Greg Chico greg@deserteng.com | 26 E Pursel Yerington, NV 89447 | 775-745-5922 | 6 | Online |
| 4 Point Engineering | fourpointengineering@gmail.com | 11 Red Canyon Rd Wellington, NV 89444 | 775-720-2089 | 7 | Online |
| Desert Engineering | Jim Chico jim@deserteng.com | 26 E Pursel Yerington, NV 89447 | 775-463-3479 (o) 775-463-9526 (f) | 8 | Online |
| Kelly Erosion Control | Kym Kelley kym@kellyerosioncontrol.com | 2395 Tampa St #B Reno, NV 89512 | (775) 322- 7755 | 9 | Online |

**MASON VALLEY CONSERVATION DISTRICT
2018 Mitchell Bank Stabilization Project
PLAN HOLDERS LIST**

1518-003

| NO. | COMPANY | CONTACT / EMAIL | ADDRESS | PHONE/ FAX | Add. |
|--------|------------------------------------|---------------------------------------------------------------------------------------------|-------------------------------------------------------------|------------------------------|--------|
| 1 | Mason Valley Conservation District | Ed Ryan paul.ryan@nv.usda.gov | 215 West Bridge Street, Suite 11A Yerington, NV 89447 | 775.223.7499 | |
| 2 | R.O. Anderson Engineering, Inc. | Shaker Gorla, P.E., CFM sgorla@roanderson.com | 1603 Esmeralda Avenue Minden, NV 89423 | 775.782.2322 775.782.7084 | |
| 3 | Sierra Contractor's Source | | 860 Maestro Drive Reno, NV 89511 | 775.329.7222 | |
| 4 | Burdick Exc. Co | Ralph Kellogg RKELLOG@Burdickexc.com | | 530-362-1089 775-296-4566 | OFFICE |
| 5 | Desert Engineering | Greg Chico grec@deserteng.com | 26 E Porsel Yerington, NV | 775-745-5922 | |
| 6 | 4point Engineering | Fourpointengineering@gmail.com | 11 Red Canyon Rd. Wellington, NV 89444 | 775-720-2089 | |
| Online | Desert Engineering | Jim Chico jim@deserteng.com | 26 E. Porsel Lane, Yerington | 775-463-3479 775-463-9526 | FAX |
| Online | | | | | |
| | | | | | |
| | | | | | |